



Jawaharlal College of Engineering and Technology

(AUTONOMOUS)

NAAC Accredited with A+ Grade
NBA Accredited Programmes (B.Tech Aeronautical Engineering, Computer Science & Engineering, Civil Engineering)
Recognized by UGC under Section 2(f) of the UGC Act 1956
An ISO 9001:2015 Certified Institution
Approved by AICTE, New Delhi, Affiliated to A P J Abdul Kalam Technological University (KTU)



NCT/JCET/317/02-2026

Date: 19/01/2026

To
Sreelakshmi Cement Bricks and Paving Tiles
Mechode, Padur, Alathur,
Palakkad-678543

TEST REPORT CEMENT BRICKS

Source of sample : Sample supplied by the customer
No. of Samples tested : 3
Customer's reference : Letter dated on 14/01/2026
Condition of samples : Satisfactory
Date of testing : 15/01/2026


Compressive Strength


Sl. No	Sample Size (mm)	Cross-sectional Area (mm ²)	Weight of Blocks (kg)	Crushing Load (kN)	Compressive strength (N/mm ²)	Average Compressive Strength (N/mm ²)
1	300 x 190 x 150	57000	19.01	213	3.74	4.18
2	300 x 190 x 150	57000	19.53	256	4.49	
3	300 x 190 x 150	57000	19.24	246	4.32	

Note:-

- Results given above refer only to the sample supplied
- This report is being issued on the specific understanding that our lab will not in any way be involved in any action following the interpretation of the above results


Yours faithfully,



LAB STAFF IN CHARGE


Counter Sign
(HOD)

Head of The Department
Department of Civil Engineering
Jawaharlal College of Engineering Technology
Jawahar Gardens, Lakkidi, Mangalam(PO)
Palakkad, Pin - 679 301




LAB IN CHARGE


Counter-Sign
(PRINCIPAL)

PRINCIPAL
Jawaharlal College of Engineering & Technology
Jawahar Gardens, Lakkidi, Mangalam, Pin-679301



(Sponsors : Nehru College of Educational and Charitable Trust)

College Campus : Jawahar Garden, Mangalam, Palakkad (Dist), Kerala - 679 301.
Tel: +91 466 - 2344800, E-mail : office@jawaharlalcolleges.com, Web: www.jawaharlalcolleges.com

